

THE CITY OF SEATTLE
BOARD OF PUBLIC WORKS

CITY LIGHT DEPARTMENT

SPECIFICATION NO. 2928

FOR

UNDERGROUND TANKS

1988 PROGRAM

To Planholders.

The attached Addendum No. 1 modifies the Bidding Documents for Underground Tanks, 1988 Program, and takes precedence over the original specification.

The section, page, and paragraph numbers in the addendum refer to the section, page, and paragraph numbers of the original specification.

Every Bidder shall acknowledge receipt of Addendum No. 1 by filling in the appropriate space in the Proposal.

Randall W. Hardy
Superintendent

By



C. T. Rockey
Chief Engineer

JOC:kp

SCL 03993

CTY0048999

SEA289478

1.01 ADDENDUM NO. 1

Addendum No. 1 to Specification No. 2928 for Underground Tanks, 1988 Program, issued on October 18, 1988 modifies the Bidding Documents by the following:

SECTION 00100 - INSTRUCTIONS TO BIDDERSPAGE 3

Paragraph 1.02 - BID OPENING: Change "October 19, 1988" to "October 26, 1988."

SECTION 00410 - WMBE REQUIREMENTSPAGE 5

Paragraph II, A - SET ASIDE PERCENTAGES: Add:

"Permits and dumping fees for disposal of PCB contaminated sludge and oil will not be eligible for inclusion in the set aside percentages for WBE or MBE."

SECTION 01025 - MEASUREMENT AND PAYMENTPAGE 7Paragraph 1.02

Item No. 20 - Removal and Disposal of PCB Contaminated Sludges and Oil:
Add:

"The lump sum price bid shall be based on the removal and disposal of a total of 550 gallons of sludge and oil with contamination levels below 20 ppm. If the quantity actually removed from the tanks varies by more than 10 percent of the amount, an equitable adjustment in payment will be made by the Engineer."

END SECTION 00900

SCL 03994

CTY0049000

SEA289479